



5 Gallons

Fire Pro Tech -50

50% Glycerine Based Anti-Freeze

- For Wet Fire Protection Sprinkler Systems
- Super Concentrate 50% Glycerine
- Meets NFPA 13 Requirement
- Non-Toxic, Non-Corrosive
- For All Type Of Pipe Including CPVC

Fire Pro Tech-50

ComStar's Fire Pro Tech-50 anti-freeze protection fluid is glycerine based, which is in compliance with the recommendations of NFPA 13. Systems using Fire Pro Tech-50 are assured flow protection of -43° F. Fire Pro Tech-50 is ready to use and should not be diluted. Check freezing protection each season using a hydrometer to test the specific gravity. The specific gravity should be at 1.130 at 60° F. If specific gravity is less than this number, meaning weakened, then empty system and replace with Fire Safe or Fire Pro Tech -100.

INSTALLATION DIRECTIONS:


1. Close the water supply valves and drain the system.
2. Add undiluted Fire Pro Tech-50 to the system through a filling cup.
3. Vent air from piping using end sprinklers.
4. To assure the system is completely filled and that all air is out of the system, open all sprinklers slightly until Fire Pro Tech-50 appears.

Installation Instructions when filling cup is not above highest sprinkler:

1. Assure that Fire Pro Tech-50 anti-freeze is put in at the highest sprinkler branch line using a filling cup.
2. The drop pipe should be filled using a filling cup as per diagram.
3. Tighten sprinkler heads and open valve marked #1 until the drop pipe and the section of pipe above valve # 1 are empty.
4. Close valve # 1, close the filling connection valve and slowly open the supply valve wide.

Contents: Glycerine (CAS# 56-81-5), Water (CAS# 7732-78-5)

Anti-Freeze for WET Fire Protection Sprinkler Systems



⚠️ **WARNING:** Cancer and Reproductive Harm- www.P65Warnings.ca.gov

STOCK NO. 35-763
5 U.S.GALLONS
(19 LITERS)



ComStar International Inc.
College Point, NY 11356 U.S.A.
www.comstarproducts.com



KEEP OUT OF REACH OF CHILDREN



HAZARD STATEMENT: Eye and Skin Irritant - may cause eye and skin irritation. **INHALATION:** Remove to fresh air, keep patient warm and at rest. If breathing is irregular or stopped, give artificial respiration. If unconscious, place in the recovery position and obtain immediate medical attention. Give nothing by mouth. **EYES:** Irrigate copiously with clean water for at least 15 minutes, holding the eyelids apart and seek medical attention. **SKIN:** Remove contaminated clothing. Wash skin thoroughly with soap and water or use a recognized skin cleanser. **INGESTION:** If swallowed, obtain immediate medical attention. Keep at rest. DO NOT induce vomiting.

ComStar International Inc. 20-47 128th Street, College Point, NY 11356 Tel: 1-800-328-0142