

# Hydro Lax

## Hydronic System Cleaner and Conditioner

- Removes Sludge from Zone Valves
- Frees Flow Valves
- Lubricates Pump Seals

### DIRECTIONS:

Mix one quart of **Hydro Lax** with one gallon of water. Introduce into system with force pump through draw-off. Use one quart for the average house (30 gallons of boiler water).

**NOTE: EXCESS Hydro Lax WILL NOT HARM ANY SYSTEM.**

**CONTENTS: Hexylene Glycol (CAS# 107-41-5).**

**HAZARD STATEMENT:** Eye and Skin Irritant - may cause eye and skin irritation.

**INHALATION:** Remove to fresh air, keep patient warm and at rest. If breathing is irregular or stopped, give artificial respiration. If unconscious, place in the recovery position and obtain immediate medical attention. Give nothing by mouth. **EYES:** Irrigate copiously with clean water for at least 15 minutes, holding the eyelids apart and seek medical attention. **SKIN:** Remove contaminated clothing. Wash skin thoroughly with soap and water or use a recognized skin cleanser. **INGESTION:** If swallowed, obtain immediate medical attention. Keep at rest. DO NOT induce vomiting.

ComStar International Inc. 20-47 128th Street. College Point, NY 11356 U.S.A. Tel: 1-800-328-0142



**WARNING:** Cancer and Reproductive Harm- [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)



**ComStar International Inc.**  
College Point, NY 11356 U.S.A.  
[www.comstarproducts.com](http://www.comstarproducts.com)

